

S.C. EGGER Technologia S.R.L.
Nr. 43 din 03.02.2020

Raport de monitorizare – Ianuarie 2020

parametru Formaldehidă (HCHO)
la coșul de dispersie – Instalație post-ardere catalitică, *Instalație FORMOX C1.36.1*
în acord cu AIM nr.11 din 26.10.2011, revizia 1 din 15.01.2014

Data		Media la 24H	limita conf. AIM nr.11 din 26.10.2011, rev.01 din 15.01.2014
01.01.2020 00:00	02.01.2020 00:00	1,84	5,00
02.01.2020 00:00	03.01.2020 00:00	1,90	5,00
03.01.2020 00:00	04.01.2020 00:00	2,18	5,00
04.01.2020 00:00	05.01.2020 00:00	2,29	5,00
05.01.2020 00:00	06.01.2020 00:00	2,31	5,00
06.01.2020 00:00	07.01.2020 00:00	1,69	5,00
07.01.2020 00:00	08.01.2020 00:00	1,68	5,00
08.01.2020 00:00	09.01.2020 00:00	1,84	5,00
09.01.2020 00:00	10.01.2020 00:00	1,93	5,00
10.01.2020 00:00	11.01.2020 00:00	1,78	5,00
11.01.2020 00:00	12.01.2020 00:00	1,85	5,00
12.01.2020 00:00	13.01.2020 00:00	1,82	5,00
13.01.2020 00:00	14.01.2020 00:00	1,77	5,00
14.01.2020 00:00	15.01.2020 00:00	1,58	5,00
15.01.2020 00:00	16.01.2020 00:00	1,54	5,00
16.01.2020 00:00	17.01.2020 00:00	1,60	5,00
17.01.2020 00:00	18.01.2020 00:00	1,45	5,00
18.01.2020 00:00	19.01.2020 00:00	1,54	5,00
19.01.2020 00:00	20.01.2020 00:00	1,46	5,00
20.01.2020 00:00	21.01.2020 00:00	1,45	5,00
21.01.2020 00:00	22.01.2020 00:00	1,54	5,00
22.01.2020 00:00	23.01.2020 00:00	1,84	5,00
23.01.2020 00:00	24.01.2020 00:00	1,73	5,00
24.01.2020 00:00	25.01.2020 00:00	1,69	5,00
25.01.2020 00:00	26.01.2020 00:00	1,98	5,00
26.01.2020 00:00	27.01.2020 00:00	1,94	5,00
27.01.2020 00:00	28.01.2020 00:00	1,87	5,00
28.01.2020 00:00	29.01.2020 00:00	1,77	5,00
29.01.2020 00:00	30.01.2020 00:00	1,48	5,00
30.01.2020 00:00	31.01.2020 00:00	1,74	5,00
31.01.2020 00:00	01.02.2020 00:00	1,90	5,00

PETROȘEL Ovidiu

Director tehnic
EGGER Technologia S.R.L.

