

Raport de monitorizare - Iulie 2025

parametru Formaldehidă (HCHO)

**la coșul de dispersie - Instalație post-ardere catalitică, Instalație FORMOX C1.36.1
în acord cu AIM nr. 11 din 26.10.2011, revizuita la data de 12.07.2021**

Data		Media la 24H	Limita conf. AIM nr.11 din 26.10.2011, revizuita la data de 12.07.2021
01.07.2025 00:00	02.07.2025 00:00	-	5
02.07.2025 00:00	03.07.2025 00:00	-	5
03.07.2025 00:00	04.07.2025 00:00	-	5
04.07.2025 00:00	05.07.2025 00:00	-	5
05.07.2025 00:00	06.07.2025 00:00	0,92	5
06.07.2025 00:00	07.07.2025 00:00	0,98	5
07.07.2025 00:00	08.07.2025 00:00	1,08	5
08.07.2025 00:00	09.07.2025 00:00	1,06	5
09.07.2025 00:00	10.07.2025 00:00	0,99	5
10.07.2025 00:00	11.07.2025 00:00	0,98	5
11.07.2025 00:00	12.07.2025 00:00	1,06	5
12.07.2025 00:00	13.07.2025 00:00	1,10	5
13.07.2025 00:00	14.07.2025 00:00	1,16	5
14.07.2025 00:00	15.07.2025 00:00	1,11	5
15.07.2025 00:00	16.07.2025 00:00	0,99	5
16.07.2025 00:00	17.07.2025 00:00	0,97	5
17.07.2025 00:00	18.07.2025 00:00	1,07	5
18.07.2025 00:00	19.07.2025 00:00	1,01	5
19.07.2025 00:00	20.07.2025 00:00	0,88	5
20.07.2025 00:00	21.07.2025 00:00	0,94	5
21.07.2025 00:00	22.07.2025 00:00	0,80	5
22.07.2025 00:00	23.07.2025 00:00	0,79	5
23.07.2025 00:00	24.07.2025 00:00	0,71	5
24.07.2025 00:00	25.07.2025 00:00	0,72	5
25.07.2025 00:00	26.07.2025 00:00	0,75	5
26.07.2025 00:00	27.07.2025 00:00	0,77	5
27.07.2025 00:00	28.07.2025 00:00	0,49	5
28.07.2025 00:00	29.07.2025 00:00	1,00	5
29.07.2025 00:00	30.07.2025 00:00	0,77	5
30.07.2025 00:00	31.07.2025 00:00	0,72	5
31.07.2025 00:00	01.08.2025 00:00	1,12	5

Obs: In intervalul 01.07.2025, ora 02:27 si 04.07.2025 ora 10:32, Instalatia Formox de pe platforma "Fabricii de adezivi EGGER Technologia" a fost oprita pentru actualizare software.

PETROȘEL Ovidiu

Administrator
EGGER Technologia S.R.L.

