

Raport de monitorizare - Iunie 2021

parametru Formaldehidă (HCHO)

**la coșul de dispersie - Instalație post-ardere catalitică, Instalație FORMOX C1.36.1
în acord cu AIM nr. 11 din 26.10.2011, revizia 1 din 15.01.2014**

Data		Media la 24H	limita conf. AIM nr.11 din 26.10.2011, rev.01 din 15.01.2014
01.06.2021 00:00	02.06.2021 00:00	3,25	5
02.06.2021 00:00	03.06.2021 00:00	3,10	5
03.06.2021 00:00	04.06.2021 00:00	2,62	5
04.06.2021 00:00	05.06.2021 00:00	2,86	5
05.06.2021 00:00	06.06.2021 00:00	2,99	5
06.06.2021 00:00	07.06.2021 00:00	3,11	5
07.06.2021 00:00	08.06.2021 00:00	3,19	5
08.06.2021 00:00	09.06.2021 00:00	3,22	5
09.06.2021 00:00	10.06.2021 00:00	3,27	5
10.06.2021 00:00	11.06.2021 00:00	3,15	5
11.06.2021 00:00	12.06.2021 00:00	3,14	5
12.06.2021 00:00	13.06.2021 00:00	3,13	5
13.06.2021 00:00	14.06.2021 00:00	3,20	5
14.06.2021 00:00	15.06.2021 00:00	3,08	5
15.06.2021 00:00	16.06.2021 00:00	3,00	5
16.06.2021 00:00	17.06.2021 00:00	3,12	5
17.06.2021 00:00	18.06.2021 00:00	2,96	5
18.06.2021 00:00	19.06.2021 00:00	2,67	5
19.06.2021 00:00	20.06.2021 00:00	2,66	5
20.06.2021 00:00	21.06.2021 00:00	2,64	5
21.06.2021 00:00	22.06.2021 00:00	2,68	5
22.06.2021 00:00	23.06.2021 00:00	2,60	5
23.06.2021 00:00	24.06.2021 00:00	2,48	5
24.06.2021 00:00	25.06.2021 00:00	2,55	5
25.06.2021 00:00	26.06.2021 00:00	2,39	5
26.06.2021 00:00	27.06.2021 00:00	2,81	5
27.06.2021 00:00	28.06.2021 00:00	2,78	5
28.06.2021 00:00	29.06.2021 00:00	3,01	5
29.06.2021 00:00	30.06.2021 00:00	3,08	5
30.06.2021 00:00	01.07.2021 00:00	2,96	5

PETROȘEL Ovidiu

Director Tehnic
EGGER Technologia S.R.L.

